

Rochester Public Utilities

Water Quality Report 2014



*In our 17th annual **Drinking Water Quality Report**,
we are pleased to announce that water
provided by Rochester Public Utilities (RPU)
meets all State and Federal drinking water standards.*

RPU is dedicated to one clear goal – Quality First.

*With a focus on customer service
and efficiency in operations,*

*we continue to strive for excellence through
effective water quality programs
that will ensure a safe and reliable
drinking water supply for years to come.*

*This report contains the results of monitoring
done on your drinking water for the period
from January 1 to December 31, 2014.*

*The purpose of this report is to advance
consumers' understanding of drinking water
and heighten awareness of the need
to protect our precious water resources.*



Source of Water

Water is pumped from 31 deep groundwater wells located throughout the city. Most wells are 24 inches in diameter and extend 400-1,000 feet in depth. Water in the Rochester municipal system is drawn from water-bearing rock layers called aquifers. An aquifer is any type of geologic material, such as sand or sandstone, which can supply water to wells or springs. Most of Rochester's water is drawn from the Jordan Aquifer, a deep sedimentary unit that underlies much of southeastern Minnesota. Water is also drawn from several multi-formation wells including: Prairie du Chien-Jordan, Prairie du Chien-Galesville, Jordan-Galesville, and Prairie du Chien-Mt. Simon aquifers.

Even though water provided to RPU customers meets all State and Federal facts drinking water standards, the Minnesota Department of Health has also made a determination as to how vulnerable the source of water may be to future contamination incidents. If you wish to obtain the entire source water assessment regarding your drinking water, please call 651-201-4700 or 800-818-9318 (and press 5) during normal business hours. Also, you can view it on line at

www.health.state.mn.us/divs/eh/water/swp/swa

Call 507-280-1500 or visit www.rpu.org if you have any questions about Rochester's drinking water or would like information about opportunities for public participation in decisions that may affect the quality of the water.



Water Treatment

Rochester's water quality is especially high due to the depth of the wells and the quality of the source; therefore there is little need for treatment. At each of our wells, the following water treatment products are added to the groundwater before it is pumped into the distribution system:

- **Fluoride** (*helps prevent tooth decay*)

State of Minnesota requires all municipal water systems add fluoride to the drinking water to promote strong teeth. A typical source of fluoride includes erosion of natural deposits, discharge from fertilizer and aluminum factories. Natural groundwater in Rochester contains 0.2 ppm fluoride. Over 3,150 fluoride tests were performed in 2014 at different residential and business sites around the city. RPU's fluoride ranged from 1.1 to 1.3 ppm, with an average level of 1.2 ppm. The Maximum Contaminant Level (MCL) and Maximum Contaminant Level Goal (MCLG) for fluoride is 4 ppm.

- **Chlorine** (*disinfects drinking water*) is added to the water at each well to minimize the chance for any bacteria, viruses, or fungi in the distribution system. Total Chlorine is measured weekly at the 25 different sites around the city averaging 0.8 ppm. The Maximum Residual Disinfectant Level (MRDL) and the Maximum Residual Disinfectant Level Goal (MRDLG) for Chlorine is 4 ppm.

- **Polyphosphate** (*used for corrosion control*) is added to our water to help prevent "rusty" water. A concentration of approximately 0.5 ppm is maintained in the distribution system. Polyphosphate is also used for corrosion control, by coating distribution mains and household piping to prevent the leaching of lead and copper from household plumbing into the drinking water.

Water Conservation

RPU continues to offer rebates on qualifying equipment purchases to promote and encourage water conservation. For full details and a list of rebates available, visit www.rpu.org. Through RPU's CONSERVE & SAVE® rebate program, a water savings of over 9 million gallons was attained.

CONSERVE & \$AVE®



Compliance with National Primary Drinking Water Regulations

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- **Radioactive contaminants**, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (EPA) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA and the Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline at 1-800-426-4791.



Results of Monitoring

No contaminants were detected at levels that violated State or Federal drinking water standards. However, some contaminants were detected in trace amounts that were below legal limits. The table that follows shows the contaminants that were detected in trace amounts last year. Some contaminants are sampled less frequently than once a year; as a result, not all contaminants were sampled for in 2014. If any of these contaminants were detected the last time they were sampled for, they are included in the table along with the date that the detection occurred. In 2014 we also collected and tested over 1,200 water samples for coliform bacteria, which we showed no bacteria present in the water.

Regulated Substances

Parameter	Units	MCLG	MCL	Range	Avg./ Results*	Typical Source of Contaminant
Alpha Emitters	pCi/l	0	15.4	ND - 9	9	Erosion of natural deposits.
Barium	ppm	2	2	NA	0.05	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chlorine **	ppm	4	4	0.4 – 1.58	0.84	Water additive used to control microbes.
Combined Radium	pCi/l	0	5.4	ND – 3	3	Erosion of natural deposits.
Haloacetic Acids (HAA5)	ppb	0	60	ND – 85.4	3.4	By-product of drinking water disinfection.
Nitrate (as Nitrogen)	ppm	10.4	10.4	ND-0.71	0.71	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
TTHM (Total trihalomethanes)	ppb	0	80	1.8 – 10	9.6	By-product of drinking water disinfection.
Tetrachloroethylene	ppb	0	5	ND – 0.64	0.49	Leaching from PVC pipes; discharge from factories and dry cleaners.
Radon	pCi/l	N/A	300	NT	153	Erosion of natural deposits.

* This is the value used to determine compliance with federal standards. It sometimes is the highest value detected and sometimes is an average of all the detected values. If it is an average, it may contain sampling results from the previous year.

** Highest and Lowest Monthly Average.

Radon

Radon is a radioactive gas which naturally occurs in some groundwater. It poses a lung cancer risk when gas is released from water into the air (as occurs during showering, bathing, or washing dishes or clothes) and a stomach cancer risk when it is ingested. Because radon in indoor air poses a much greater health risk than radon in drinking water, an Alternative Maximum Contaminant Level (ACML) of 4,000 picoCuries per liter (pCi/l) may apply in states that have adopted an Indoor Air Program, which compels citizens, homeowners, schools, and communities to reduce the radon threat from indoor air. For states without such a program, the Maximum Contaminant Level (MCL) of 300 pCi/l may apply. Minnesota plans to adopt an Indoor Air Program once the Radon Rule is finalized.

Key

MCL (Maximum Contaminant Level) Highest level of a contaminant allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal) Level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

N/A Not Applicable.

ND. Not Detected.

NT. Not Tested.

ppm Parts per million.

ppb Parts per billion.

gpg Grains per gallon.

PCi/L Pico curies per liter (a measure of radioactivity).

Range Lowest to the highest a contaminant was detected in 2014.

AL Action Level is the concentration of a contaminant which triggers treatment or another requirement which a water system must follow.

90% Level. .90% of samples must be below the AL.

SMCL Secondary Maximum Contaminant Level.

Ntu Nephelometric units.



Unregulated Substances

Parameter	Units	SMCL	Avg./Results	Effects – Source
Alkalinity	ppm	N/A	260	Carbonate rocks (limestone)
Aluminum	ppm	0.05 to 0.2	0.005	Colored water
Calcium	ppm	N/A	72	Mineral deposits from rock.
Chloride	ppm	250	4.67	Salty taste
Hardness, Total	ppm	N/A	283	Mineral deposits
Hardness, Total	gpg	N/A	17	Mineral deposits
Iron	ppm	0.3	0.28	Rusty color, staining, metallic taste
Manganese	ppm	0.05	0.04	Black-to-brown color, staining, metallic taste
Magnesium	ppm	N/A	24.5	Mineral deposits from rock.
pH	pH	6.5 to 8.5	7.5	Corrosion, metallic taste if below 6.5; deposits, slippery feel, soda taste if above 8.5
Sodium	ppm	20	10	Salty taste – Erosion of natural deposits. (range 1.25 to 10)
Sulfate	ppm	250	45.9	Laxative effect – Erosion of natural deposits. (range 10.6 to 45.9)
Total Dissolved Solids	ppm	500	330	Hardness, deposits, colored water, staining, salty taste
Turbidity	Ntu	N/A	<1	Refers to how clear the water is.

Regulated Substances Controlled in the Distribution System

Substance	MCLG	AL	90% Level	# of sites over AL	Meets Regulations	Typical Source
Lead (ppb) (7/12/2013)	0	15	6.4	1 out of 50	Yes	Corrosion of household plumbing systems; Erosion of natural deposits.
Copper (ppm) (7/12/2013)	1.3	1.3	0.66	1 out of 50	Yes	Corrosion of household plumbing systems; Erosion of natural deposits.

(see Key on page 9)

Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from material and components associated with service lines and home plumbing. RPU is responsible for providing high quality drinking water, but cannot control the variety of material used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in our water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Monitoring may have been done for additional contaminants that do not have MCLs established for them and are not required to be monitored under the Safe Drinking Water Act. Results may be available by calling 651-201-4700 or 1-800-818-9318 during normal business hours.

Monitoring for unregulated contaminants as required by U.S. Environmental Protection Agency rules (40 CFR 141.40) was conducted in 2014. Results of the unregulated contaminant monitoring are available upon request from Cindy Swanson, Minnesota Department of Health, at 651-201-4656.



Visit RPU's interactive water exhibits to learn how you can conserve and help keep our water clean!



Cascade Meadow Wetlands & Environmental Science Center

2900 19th Street NW, Rochester

For hours and events visit:
www.cascademeadow.org



Rochester Public Utilities
4000 East River Road NE
Rochester, MN 55906-2813
800.778.3421 | 507.280.1500
www.rpu.org